



STAFF REPORT

Meeting Date: March 2, 2015

Agenda Item #: 9c

TO: Mayor and Town Council
FROM: Kevin Dempsey Fire Department
THUR: Susan Parker, Town Administrator
TITLE: **Amendment to Chapter 95 Section 95.07 (a)**

Summary: Currently Ordinance 95.07 (a) is incorrect. It states that no obstructions may be placed within a (30) foot perimeter of any access. The area, which needs to be clear, would be in the form of a rectangle 30 foot wide and 12 foot deep. Therefore the total footprint is a (84) foot perimeter.

Recommendation: Move to adopt the amendment for Ordinance 95.07 (a).